

Type test Certificate of complete type test

Gök-Nur Baki LTD

Baku, Azerbaijan

has successfully passed the type test sequence on a

multi-core power cable

Type: NYY (Cu/PVC/PVC), 3x120 mm², 1x70 mm²

Rating: 0,6/1(1,2) kV – 3x120 mm² – 1x70 mm² – Cu – PVC

The test object passed the required clauses of


IEC 60502-1

The test results are recorded in Certificate No.

TIC 1031-14

This Certificate is issued on 11 August 2014

KEMA Nederland B.V.



S.A.M. Verhoeven
Director Testing, Inspections & Certification The Netherlands

Copyright © KEMA Nederland B.V.

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the apparatus will prevail. This document does not imply that KEMA has certified or approved any apparatus other than the specimen tested.